

---

## CERTIFICATE OF APPROVAL

### No CAF 174

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

**Designated CERTIFIRE Approved Door and Blank Manufacturers  
as Converted by**

## **ARBOR FOREST PRODUCTS LTD**

**Barrow Road, New Holland, North Lincolnshire, DN19 7RR**  
**Tel: 01469 532300 Fax: 01469 531867**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---


#### **SCOPE OF APPROVAL**

**Approved for the manufacture  
of door frames for use with  
specified CERTIFIRE approved  
fire doors**

#### **TECHNICAL SCHEDULE**

**TS10 Fire Resisting Door  
Assemblies with non-  
Metallic Leaves**

**Signed and sealed for and on behalf of Exova (UK) Limited trading as  
Warrington Certification**



**Sir Ken Knight  
Chairman  
Impartiality Committee**



**Paul Duggan  
Certification Manager**



Issued: 1<sup>st</sup> June 2016  
Reissued: 13<sup>th</sup> January 2017  
Valid to: 9<sup>th</sup> May 2021

Page 1 of 3



---

## CERTIFICATE No CAF 174

### ARBOR FOREST PRODUCTS LTD

---

1. This approval relates to the manufacture of either timber or MDF door frames for use with specified CERTIFIRE approved fire doors. Subject to the under mentioned conditions, the doors when fitted in the frame and with hardware and seals specified in the door leaf certificate are designed to meet the requirements as detailed in the relevant certificates.
2. The timber door frames shall be of the following specifications/references:

**Timber Fire Check Casings:**

63 x 100 F/s 58 x 94  
63 x 115 F/s 58 x 108  
63 x 140 F/s 58 x 133  
63 x 150 F/s 58 x 144  
50 x 150 F/s 44 x 144  
50 x 100 F/s 44 x 95  
50 x 115 F/s 44 x 108  
50 x 140 F/s 44 x 133  
63 x 115 F/s 50 x 100

**Timber Fire Check Linings:**

38 x 115 F/s 30 x 108  
38 x 140 F/s 30 x 133

The timber to be utilised is stated to be redwood or whitewood of nominal density 450 kg/m<sup>3</sup>, at nominal moisture content of 12%.

3. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'
4. All timber and MDF frames shall be manufactured in accordance with the frame specification as defined in the door data sheet having regard to the maximum door leaf sizes and configurations permitted under the door certification.
5. Processing is conducted in accordance with Arbor Forest Products Ltd procedures.
6. The process is approved on the basis of production surveillance under ISO 9001: 2008.
7. The approval relates to on-going production.
8. Approved timber or MDF frames carry a label identified with Arbor Forest Products Ltd name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

## CERTIFICATE No CAF 174 ARBOR FOREST PRODUCTS LTD

9. The certified doors for which the provision of timber door frame kits is approved are as follows:

Manufacturer	Certificate Number	Timber Door Product – Timber Frame
Premdor Crosby Ltd	195	FD30 Flush
	198	FD30 Moulded Skin Chipboard Core
	240	FD30 PremCORE
Jeld-Wen UK Ltd	160	FD30 Flush timber door assemblies
	271	FD30 timber door assemblies
	192	FD30 Timber Door Assemblies with Non (Tubeboard Construction)
Vicaima Ltd	218	(Standard Duty Core) Timber Door Assemblies
J B Kind Limited & Irmade	154	FD30 timber door assemblies
Norma Doors Technologies S.A.	292	FD30 timber door assemblies
Corinthian Industries	433	FD30 Panelled door assemblies

The scope of approval and field of application for the doors is contained in the above referenced certificates.

10. The certified doors for which the provision of MDF door frame kits is approved are as follows:

Manufacturer	Certificate Number	Timber Door Product – MDF Frame
Premdor Crosby Ltd	195	FD30 Flush
	198	FD30 Moulded Skin Chipboard Core
	240	FD30 PremCORE
Jeld-Wen UK Ltd	160	FD30 Flush timber door assemblies
	192	FD30 Timber Door Assemblies with Non (Tubeboard Construction)
Vicaima Ltd	218	(Standard Duty Core) Timber Door Assemblies
Norma Doors Technologies S.A.	292	FD30 timber door assemblies
Corinthian Industries	433	FD30 Panelled door assemblies

The scope of approval and field of application for the doors and MDF frames / linings is contained in the above referenced certificates.